Energy performance certificate (EPC)

28 SHENLEY PAVILIONS CHALKDELL DRIVE SHENLEY WOOD MILTON KEYNES MK5 6LB Energy rating

Valid until: 18 July 2031

Certificate number: 3865-2297-6807-3971-0983

Property type

B1 Offices and Workshop businesses

Total floor area


111 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is C.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

31 B

If typical of the existing stock

90 D

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Air Conditioning
Assessment level	3
Building emission rate (kgCO2/m2 per year)	54.67
Primary energy use (kWh/m2 per year)	323

Recommendation report

Guidance on improving the energy performance of this property can be found in the <u>recommendation report</u> (/energy-certificate/2435-8780-6405-3248-6689).

Who to contact about this certificate

Contacting the assessor

Date of certificate

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Carolyn Clay
Telephone	07879 417061
Email	info@oakwoodps.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/019785
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk
About this assessment Employer	Oakwood Property Surveys Ltd
	Oakwood Property Surveys Ltd 34 Dulverton Drive, Furzton, Milton Keynes, MK4 1DF
Employer	

19 July 2021